

TEST RESULTS WHICH SHOWED ELEVATED LEVELS**OF LEAD IN THE DRINKING WATER****AT OR ABOVE 15 PPB**

NUMBER	SAMPLE #	BUILDING	LOCATION TESTED	RESULTS
1	C-8	Hillis Field	Men's Bathroom Sink	22 ppb
2	C-9	Hillis Field	Women's Bathroom Sink	21 ppb
3	B-4	Bus Garage	Unisex Bathroom Sink on outside of Bus Garage Right hand door	27 ppb
4	B-6	Bus Garage	Exterior Spigot	36 ppb
5	1	Elementary	Boiler room Sink	61 ppb
6	4	Elementary	Room 105 Room Sink	31 ppb
7	9	Elementary	Room 104 Room Sink	29 ppb
8	10	Elementary	Room 103 Bathroom Sink	580 ppb
9	11	Elementary	Room 103 Fountain	36 ppb
10	12	Elementary	Room 103 Room Sink	42 ppb
11	13	Elementary	Room 102 Bathroom Sink	17 ppb
12	16	Elementary	Room 101 Bathroom Sink	28 ppb
13	17	Elementary	Room 101 Fountain	27 ppb
14	18	Elementary	Room 101 Room Sink	22 ppb
15	20	Elementary	Women's staff bathroom across from rm. 101 right hand sink	21 ppb
16	22	Elementary	Mechanical room 110 (upstairs) Utility Sink	87 ppb
17	29	Elementary	Main Office Sink	43 ppb
18	30	Elementary	Principal's Office sink	38 ppb
19	39	Elementary	Room 153 Bathroom Sink	23 ppb
20	40	Elementary	Room 154 Bathroom Sink	25 ppb
21	43	Elementary	Room 155 Bathroom Sink	15 ppb
22	44	Elementary	Room 155 Sink	21 ppb
23	49	Elementary	Room 174 Sink	16 ppb
24	52	Elementary	Corridor near rm. 158 Women's Bathroom sink	15 ppb
25	72	Elementary	Room 165 Fountain	45 ppb
26	73	Elementary	Room 165 sink	35 ppb
27	79	Elementary	Room 147 Bathroom Sink	15 ppb
28	82	Elementary	Room 148 Sink	33 ppb
29	83	Elementary	Room 148 Fountain	26 ppb
30	84	Elementary	Room 148 Bathroom Sink	23 ppb
31	87	Elementary	Room 146 Bathroom Sink	21 ppb
32	88	Elementary	Room 145 Bathroom Sink	78 ppb
33	91	Elementary	Nurses Office Left hand sink	61 ppb
34	92	Elementary	Nurses Office Right hand Sink	40 ppb
35	97	Elementary	Room 143 Bathroom Sink	51 ppb
36	102	Elementary	Room 142 Bathroom Sink	23 ppb
37	103	Elementary	Room 141 Sink	18 ppb
38	140	Elementary	Kitchen Utility Closet Mop Sink	18 ppb
39	144	Elementary	Kitchen hand wash sink	16 ppb
40	146	Elementary	Court yard Exterior spigot	98 ppb
41	147	Elementary	Exterior Spigot Front of building	46 ppb
42	148	Elementary	Exterior Spigot Front of Building	59 ppb
43	150	Elementary	Exterior Spigot without cover	190 ppb

**** ppb stand for parts per billion**