

TEST RESULTS WHICH SHOWED ELEVATED LEVELS
OF LEAD IN THE DRINKING WATER
AT OR ABOVE 15 PPB

NUMBER	SAMPLE #	BUILDING	LOCATION TESTED	RESULTS
1	1	HS/MS	Boiler room spigot	66 ppb
2	2	HS/MS	Boiler room staff bathroom sink	54 ppb
3	3	HS/MS	Drama storage room sink	1700 ppb
4	4	HS/MS	Stage storage bathroom sink	48 ppb
5	5	HS/MS	Basement Janitor's supply room sink	19 ppb
6	6	HS/MS	Basement Janitor's supply room spigot	18 ppb
7	7	HS/MS	Basement old break room men's bathroom sink	93 ppb
8	8	HS/MS	Basement old break room women's bathroom sink	160 ppb
9	12	HS/MS	Basement Pool equipment room Spigot	15 ppb
10	13	HS/MS	Swim office Bathroom sink	40 ppb
11	14	HS/MS	Pool Access Bathroom sink	43 ppb
12	25	HS/MS	High School Room 145 (Art Room) Storage room sink	100 ppb
13	26	HS/MS	High School Room 142 Single Sink	21 ppb
14	38	HS/MS	Janitor's Closet slop sink across from room 104	16 ppb
15	39	HS/MS	High School Women's Locker room office sink	40 ppb
16	43	HS/MS	High School Women's Locker room spigot	49 ppb
17	45	HS/MS	Auditorium Janitor's Closet Slop sink	610 ppb
18	47	HS/MS	High School Room 109B Spigot	960 ppb
19	49	HS/MS	High School Room 109G Spigot	450 ppb
20	50	HS/MS	High School Room 109 Janitor's Slop sink	34 ppb
21	54	HS/MS	High School Room 115 Single wall sink (Science Room)	45 ppb
22	55	HS/MS	High School Room 115 Outside sink (Science Room)	61 ppb
23	56	HS/MS	High School Room 115 Inside sink (Science Room)	150 ppb
24	57	HS/MS	High School Room 115 Wall sink (Science Room)	79 ppb
25	58	HS/MS	High School Room 115 Desk sink (Science Room)	40 ppb
26	60	HS/MS	High School Room 117 Left sink (Science Room)	120 ppb
27	61	HS/MS	High School Room 117 Right sink (Science Room)	67 ppb
28	62	HS/MS	High School Room 117 left sink (Science Room)	150 ppb
29	63	HS/MS	High School Room 117 Right sink (Science Room)	62 ppb
30	64	HS/MS	High School Room 117 Desk Sink (Science Room)	130 ppb
31	72	HS/MS	High School Room 118 Fume hood sink (Science Room)	140 ppb
32	86	HS/MS	High School Room 105B Sink	30 ppb
33	88	HS/MS	High School Room 121 Sink	170 ppb
34	90	HS/MS	High School Library Men's bathroom Sink	21 ppb
35	92	HS/MS	High School Room 126A sink	83 ppb
36	93	HS/MS	High School Room 122 sink	32 ppb
37	109	HS/MS	Kitchen Ice Machine	91 ppb
38	142	HS/MS	Middle School Room 118 Desk Sink (Science Room)	410 ppb
39	143	HS/MS	Middle School room 118 inside Sink (Science Room)	190 ppb
40	144	HS/MS	Middle School room 118 Outside sink (Science Room)	190 ppb
41	145	HS/MS	Middle School room 118 inside sink (Science Room)	130 ppb
42	146	HS/MS	Middle School room 118 outside sink (Science Room)	118 ppb
43	147	HS/MS	Middle School room 118 Inside Sink (Science Room)	110 ppb

44	148	HS/MS	Middle School room 118 outside sink (Science Room)	59 ppb
45	149	HS/MS	Middle School room 118 Inside Sink (Science Room)	120 ppb
46	150	HS/MS	Middle School room 118 outside sink (Science Room)	120 ppb
47	150	HS/MS	Middle School room 118 Inside Sink (Science Room)	120 ppb
48	152	HS/MS	Middle School room 118 outside sink (Science Room)	98 ppb
49	153	HS/MS	Middle School room 118 Inside Sink (Science Room)	39 ppb
50	154	HS/MS	Middle School room 118 outside sink (Science Room)	130 ppb
51	160	HS/MS	Middle School Room 106 Desk sink (Science Room)	190 ppb
52	161	HS/MS	Middle School Room 106 Interior sink (Science Room)	74 ppb
53	162	HS/MS	Middle School Room 106 outside sink (Science Room)	91 ppb
54	163	HS/MS	Middle School Room 106 Interior sink (Science Room)	77 ppb
55	164	HS/MS	Middle School Room 106 outside sink (Science Room)	91 ppb
56	165	HS/MS	Middle School Room 106 Interior sink (Science Room)	110 ppb
57	166	HS/MS	Middle School Room 106 outside sink (Science Room)	94 ppb
58	167	HS/MS	Middle School Room 106 outside sink (Science Room)	120 ppb
59	168	HS/MS	Middle School Room 106 Interior sink (Science Room)	210 ppb
60	169	HS/MS	Middle School Room 106 Interior sink (Science Room)	71 ppb
61	170	HS/MS	Middle School Room 106 outside sink (Science Room)	100 ppb
62	171	HS/MS	Middle School Room 106 Interior sink (Science Room)	32 ppb
63	172	HS/MS	Middle School Room 106 outside sink (Science Room)	63 ppb
64	173	HS/MS	Middle School Women's room hall/109 sink	16 ppb
65	175	HS/MS	Middle School Men's room hall/109	20 ppb
66	187	HS/MS	Middle School Hall/226 Janitor's mop sink	17 ppb
67	188	HS/MS	Hall/226 Men's sink	24 ppb
68	195	HS/MS	High School Room 216 Interior sink (Science Room)	24 ppb
69	196	HS/MS	High School Room 216 outside sink (Science Room)	18 ppb
70	198	HS/MS	High School Room 216 interior room – hood sink (Science Room)	52 ppb
71	206	HS/MS	High School Room 218 wall faucet (Science Room)	190 ppb
72	207	HS/MS	High School Room 216 Wall faucet (Science Room)	81 ppb
73	214	MS/HS	High School Room 212 sink	64 ppb
74	215	MS/HS	High School Room 210 sink	26 ppb
75	216	MS/HS	High School Room 208 sink	59 ppb
76	217	MS/HS	High School Room 209G Sink	26 ppb
77	218	MS/HS	High School Room 209B Sink	29 ppb
78	219	MS/HS	High School Room 205 sink	44 ppb
79	224	MS/HS	High School Room 222B sink	27 ppb
80	226	MS/HS	High School Room H120 wall Spigot	800 ppb
81	227	MS/HS	High School Room H118 Wall Spigot	51 ppb
82	228	MS/HS	High School Men's Locker room under sink	130 ppb
83	229	MS/HS	Exterior Spigot	180 ppb
84	230	MS/HS	Exterior Spigot	100 ppb
85	231	MS/HS	Exterior Spigot	130 ppb
86	232	MS/HS	Exterior Spigot	29 ppb
87	236	MS/HS	Exterior Spigot	68 ppb
88	240	MS/HS	Exterior Spigot	28 ppb

**** ppb stand for parts per billion**